

HIMACHAL PRADESH  
PUBLIC WORKS DEAPRTMENT

No. PWI/CB/WA/Misc. Building/2023-24/ 5816-17  
To

Dated:- 29/11/25

✓ The Principal,  
Lotus Sr. Sec. School Indora,  
Vill. Kursawn, P/O. Channour,  
Distt. Kangra (HP).

Subject: - Regarding requisite of Building Safety Certificate.

Reference: - Your office Letter No. 244/ 2025 dated 19.11.2025.

The School Building Safety Certificate for the year  
2026-27 as requested vide letter quoted under reference is sent herewith.

DA/ Copy of Certificate.

  
Executive Engineer,  
Indora Division, HP.PWD.  
Indora

Copy to the Assistant Engineer, Sub Division, HP.PWD.  
Indora for information w.r.t. his office Letter No. 468 dated 24.11.2025.

↑  
Executive Engineer,  
Indora Division, HP.PWD.  
Indora.


## CERTIFICATE

The inspection of School building of Lotus Sr. Sec. Public School, Indora, Tehsil Indora, Distt. Kangra (HP) has been conducted by the concerned Junior Engineer. On the basis of their inspection report, it has been found that no earthquake resistant norms have been adopted for the construction of School building. No structural drawing approved by the competent Govt. agency were produced by School authority. The structure of the building is a non-Engineering structure. Hence the structural safety of building can not be ensured specially from earth quake point of view. This department will not be responsible for any type of loss of the life and property etc. ,if this structure fails under any circumstances.

However as per visual inspection, the building appears to be safe and accordingly, the Building Safety Certificate is being issued by this Department from 01.04.2026 to 31.03.2027. This Department could not access the structural safety of said building as the same was not constructed under the supervision of this Department.


Place:- Indora

Dated :- ~~22.11.2025~~

  
Junior Engineer,  
Indora Sub Division  
HP.PWD, Indora

  
Assistant Engineer,  
Indora Sub Division  
HP.PWD, Indora

  
Executive Engineer,  
Indora Division  
HP.PWD, Indora

  
29/11/2025